


POS. 3: FIRE DESIGN EX. 5.2

fire design EC 3-1-2 (12.10), NA: Deutschland

1. input report



steel

steel grade S235

material safety factor

resistance of cross-sections $\gamma_{M0} = 1.00$

resistance of components in the event of fire $\gamma_{M,fi} = 1.00$

geometry

section IPE300

cross-section temperature

thermal action due to the standard curve, fire resistance time $t = 90$ min

shadow effect of the section by wall/ceiling top

thermal insulation protection by Faser-Zement-plated structures:

thermal conductivity $\lambda_p = 0.15$ W/(m·K), specific heat capacity $c_p = 1200$ J/(kg·K), maximum density $\rho_p = 800$ kg/m³

thickness of insulating material $d_p = 20.2$ mm

resistance

plastic verification incl. c/t-verification

fire design at temperature level

adjustment factors for uneven temperature distribution

across the cross section $\kappa_1 = 0.85$, along the beam $\kappa_2 = 1.00$

internal forces and moments (event of fire)


σ -generating forces (N, M) work at centroid, τ -generating forces (V, T_t) work at shear center

Lk 1: $M_{y,fi} = 67.60$ kNm

Lk 2: $V_{z,fi} = 67.60$ kN

notes

stability is not investigated.




2. cross-section temperature

internal development of the fire-stressed box $A_p = 750.0$ mm²/mm

section factor of the protected component $A_p/V = 750.0 / 5381.2 \cdot 10^3 = 139.4$ 1/m

temperature development:



temperature in °C
fire time in min
max $T_a = 557.2$ °C
max $t = 90$ min

cross-section temperature acc. to $t = 90$ min: $T_a = 557.2$ °C

3. Lk 1

3.1. fire design

internal forces and moments (event of fire, uneven temperature distribution): $M_{y,fi} = 57.46 \text{ kNm}$

3.1.1. plastic verification

3.1.1.1. verification at temperature level

Utilisation rate at time $t = 0$ (normal temperature)

plastic verification for $M_y = 57.46 \text{ kNm}$

max. load factor of normal stresses (plastic): $f_{\sigma,pl} = 2.570 \Rightarrow U_{\sigma,pl} = 0.389$

verification: $U_{pl} = 0.389 < 1$ **ok**

critical temperature $T_{a,cr} = 39.19 \cdot \ln[1/(0.9674 \cdot \mu_0^{3.833}) - 1] + 482 = 624.0 \text{ °C}$ with $\mu_0 = 0.389$

existing temperature $T_a = 557.2 \text{ °C}$

verification: $U_T = T_a/T_{a,cr} = 0.893 < 1$ **ok**

cross-section in class 1, material coefficient $\varepsilon = 0.85 \cdot (235/235.0)^{0.5} = 0.850$

c/t-verification: outstand flange: utilization $U_{c/t} = 0.621 < 1$ **ok**

internal compression parts: utilization $U_{c/t} = 0.496 < 1$ **ok**

total: utilization $U_{c/t} = 0.621 < 1$ **ok** (reg. section class 2)

4. Lk 2

4.1. fire design

internal forces and moments (event of fire, uneven temperature distribution): $V_{z,fi} = 67.60 \text{ kN}$

4.1.1. plastic verification

4.1.1.1. verification at temperature level

Utilisation rate at time $t = 0$ (normal temperature)

plastic verification for $V_z = 67.60 \text{ kN}$

max. load factor of shear stresses (plastic): $f_{\tau,pl} = 4.272 \Rightarrow U_{\tau,pl} = 0.234$

verification: $U_{pl} = 0.234 < 1$ **ok**

critical temperature $T_{a,cr} = 39.19 \cdot \ln[1/(0.9674 \cdot \mu_0^{3.833}) - 1] + 482 = 701.3 \text{ °C}$ with $\mu_0 = 0.234$

existing temperature $T_a = 557.2 \text{ °C}$

verification: $U_T = T_a/T_{a,cr} = 0.795 < 1$ **ok**

5. final result

maximum utilization [Lk 1]:	temperature	max $U_T = 0.795 < 1$ ok
	stress	max $U_{\sigma,t=0} = 0.389 < 1$ ok
	c/t-ratio	max $U_{c/t} = 0.621 < 1$ ok
	resistance	max $U = 0.893 < 1$ ok

verification succeeded

6. Regulations

DIN EN 1990, Eurocode 0: Grundlagen der Tragwerksplanung;

Deutsche Fassung EN 1990:2002 + A1:2005 + A1:2005/AC:2010, Ausgabe Dezember 2010

DIN EN 1990/NA, Nationaler Anhang zur DIN EN 1990, Ausgabe Dezember 2010

DIN EN 1991-1-2, Eurocode 1: Einwirkungen auf Tragwerke - Teil 1-2: Allgemeine Einwirkungen -

Brandeinwirkungen auf Tragwerke; Deutsche Fassung EN 1991-1-2, Ausgabe Dezember 2010

DIN EN 1991-1-2/NA, Nationaler Anhang zur DIN EN 1991-1-2, Ausgabe September 2015

DIN EN 1993-1-2, Eurocode 3: Bemessung und Konstruktion von Stahlbauten - Teil 1-2: Allgemeine Regeln -

Tragwerksbemessung für den Brandfall; Deutsche Fassung EN 1993-1-2, Ausgabe Dezember 2010

DIN EN 1993-1-2/NA, Nationaler Anhang zur DIN EN 1993-1-2, Ausgabe Dezember 2010